

**TOWN OF ZIONSVILLE, INDIANA  
2009 SEWER REPLACEMENT PROJECT**

**ADDENDUM NO. 2  
TO DRAWINGS AND SPECIFICATIONS  
HNTB JOB NO. 39630-PL-006-012**


The following changes shall be made to the contract documents. Please note: the contractor must acknowledge receipt of this addendum in the appropriate place on the Proposal Form when submitting a bid.

**ITEM 1 DRAWING SHEET NO. 4 – HAWTHORNE STREET PLAN**

**CORRECTION:** The note on sheet 4 that describes the sewer segment between new manhole # 06-09D & existing manhole 06-9C indicates the sewer slope is to be 0.5% shall be changed to read 5.0%. Also in addendum #1, Item 1 it was indicated to change the invert elevation of manhole #06-09D from 863.90 to invert elevation 853.90. By changing the slope of the sewer to 5.0% it will change the invert elevation back to the original elevation of 863.90.

ISSUED: July 27, 2009

HNTB CORPORATION



Darren C. Burkhart, P.E.  
Registered Engineer No. 1900126  
State of Indiana

